NOTIFIER by Honeywell

Technical Bulletin

NFS-640 Panel Version 3.8.3 Firmware Release Notice

May 31, 2006

Document TB06-05-01

NOTIFIER has released new NFS-640 (640) software, version 3.8.3, which corrects the issue identified in Technical Bulletin TB06-04-01. Version 3.8.3 was released to production in May of 2006, and is currently posted on Magni-Fire.com.

The software version of an installed 640 panel can be confirmed via panel lamp test, VeriFire Tools, NCS or by the 4 digit date code sticker located next to connector J4 (the KDM-2 keypad connector) on the CPU-640 board. Any CPU-640 with a date code of 1806 or later comes with version 3.8.3 installed.

In addition to correcting the anomaly identified in Technical Bulletin TB06-04-01, where a silenceable output may automatically reactivate after it has been signal silenced, version 3.8.3 is required for a 640 to be used on Noti-Fire-Net version 5.0 or higher with either an NCA-2 or NFS2-3030 (See Magni-Fire.com for download of this software version).

Technical questions regarding this bulletin should be addressed to NOTIFIER Technical Services.