

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7275-0559:0170 Page 1 of 1

CATEGORY: 7275 -- COMBINATION SMOKE/CO DETECTOR-PHOTOELECTRIC TYPE

LISTEE: SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models SK-FIRE-CO and IDP-FIRE-CO combination multi-criteria photoelectric smoke and Carbon Monoxide detector with supplement heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 15-32 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, NFPA 720, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as smoke detectors for use with Model B200S base and listee's separately listed compatible fire alarm control units. Also suited for gas and vapor detection. The supplemental heat sensor is intended for use to reduce the nuisance alarm and is not intended for use as a stand alone heat detector.

XLF: 7275-0028:0264

12-13-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division