

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7150-0559:0121

Page 1 of 1

**CATEGORY:** 7150 -- FIRE ALARM PULL BOXES

**LISTEE:** SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927  
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464  
Email: mike.mcisaac@honeywell.com

**DESIGN:** Models PS-DATH, PS-DATK, PS-SATH, PS-SATK and PS-SAWH non coded manual pull stations with hex lock or key lock. Model with suffix -DATH or -DATK indicates push bar type and suffix -SATH, -SATK or -SAWH indicate no push bar type, followed by O (outdoor, has gasket) or I (indoor, no gasket).

Model PS-WPB back box (for outdoor) and Model PS-BB back box (for indoor) must be installed with the unit. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed and compatible fire alarm control units. Suitable for indoor and outdoor use.

\* These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments.

**XLf:** 7150-1408:0107

\*Updated 06-22-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*