

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3240-0559:0139 Page 1 of 1

CATEGORY: 3240 -- DUCT SMOKE DETECTOR HOUSING/BASE

LISTEE: SILENT KNIGHT SECURITY 1985 Douglas Drive, MN10-212A, Golden Valley, MN 55422
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models SD505-ADHR duct smoke detector housing with relay and SD-505-DTS detector test station. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as a duct smoke detector housing/base and test station for use only with listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

*Rev. 06-13-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division