

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:0160

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models IFP-2000-VIP Fire Alarm Control Units. Power limited, automatic, manual, waterflow, sprinkler supervisory, local, emergency Communication and Relocation, remote station (PPU), central station (PPU) services. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

IFP-2000 VIP: Control Unit
RPS-2000: Power Expander/Supply
RA-2000: Annunciator
5220: Polarity Reversal Module
5496: Intelligent Power Module
5815XL: SLC Expander Module
5824: Printer Interface
5865-3/5965-4: LED Annunciator
5880: LED IO Module
5883: Relay Interface Module
IFP-RPT: Network repeater
IDP-Relay: Relay Module
RBB: Battery Box
VIP-50, *VIP-125: Amplifier
VIP-VCM: Voice Control Module
VIP-SW16: LED Annunciator
VIP-CE4: Speaker Expander Module
VIP-RM: Remote Microphone Module
VIP-RM 2000: Remote Microphone

RATING: 120 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as commercial fire alarm control unit for use with separately listed initiating and indicating devices. Refer to listee's Installation Instruction Manual for details. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for

*Rev. 04-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division

total evacuation) in accordance with NFPA 72, 2002 Edition and meets the requirements of UL Standard 864, 9th Edition.

NOTE:

Suitable for high-rise application when used in conjunction with VIP-50/VIP-125* Amplifier and VIP-VCM Voice Control Module, two-way firefighter telephone.

*Rev. 04-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division