

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-1653:0199 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 377-6580 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Models PDRP-2001 and PDRP-2001E conventional fire alarm control unit. Each unit employ six programmable input circuits, four programmable output circuits, and three relay contact outputs for alarm, trouble, and supervisory signals. These units do not contain an integral digital alarm communicator transmitter (DACT). The "E" suffix represents 240 V ac 50 Hz rated units.
Models PDRP-2001 and PDRP-2001E are intended for water release, deluge, and pre-action control.
FLPS-7 Power Supply module
4XTM Transmitter module
CAC-5X Converter module
ANN-80 LCD Annunciator
ANN-I / O LED Driver module
ANN-LED Annunciator module
ANN-RLY Relay module
ANN-S / PG Serial/Parallel printer module
DP-51050 Dress panel
DP-51050LED Dress panel

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use as a pre action, deluge and agent releasing panel. Units also provide fire detection, signaling and protection features. Refer to manufacturer's Installation Manual for details.
This control unit meets the requirements of UL-864, 9th Edition Standards.

XLF: 7165-0075:0216

08-07-07 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division