

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-1653:0199

Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174  
Contact: Trish Linhart (630) 377-6580 Fax (630) 377-7245  
Email: trish.linhart@systemsensor.com

**DESIGN:** Models PDRP-2001 and PDRP-2001E conventional fire alarm control unit. Each unit employ six programmable input circuits, four programmable output circuits, and three relay contact outputs for alarm, trouble, and supervisory signals. These units do not contain an integral digital alarm communicator transmitter (DACT). The "E" suffix represents 240 V ac 50 Hz rated units.

Models PDRP-2001 and PDRP-2001E are intended for water release, deluge, and pre-action control.

FLPS-7 Power Supply module

4XTM Transmitter module

CAC-5X Converter module

ANN-80 LCD Annunciator

ANN-I / O LED Driver module

ANN-LED Annunciator module

ANN-RLY Relay module

ANN-S / PG Serial/Parallel printer module

DP-51050 Dress panel

DP-51050LED Dress panel

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control unit for use as a pre action, deluge and agent releasing panel. Units also provide fire detection, signaling and protection features. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 9th Edition Standards.

**XLF:** 7165-0075:0216

08-07-07 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGAN, Program Coordinator**  
*Fire Engineering Division*