



## UQGS.S6228 Heat-automatic Fire Detectors

[Page Bottom](#)

### Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)**SILENT KNIGHT BY HONEYWELL**

S6228

7550 MERIDIAN CIR

MAPLE GROVE, MN 55369 USA

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
<b>IDP-Heat</b>	FT	D1	-	135	50	25
<b>IDP-Heat-HT</b>	FT	D1	-	190	50	25
<b>IDP-Heat-ROR</b>	FT/ROR	None	-	135	50	25
<b>SD505-AHS</b>	FT	None	-	135-150	70	25
<b>SD505-HEAT</b>	FT/ROR	D2	-	135-194	70	35
<b>SK-HEAT</b>	FT	D1	-	135	50	25
<b>SK-HEAT-HT</b>	FT	D1	-	190	50	25
<b>SK-HEAT-ROR</b>	FT/ROR	None	-	135	50	25

Base Model	Related Detector	Control Unit Compatibility Restrictions
<b>SD505-6AB</b>	SD505-APS	None

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

[Last Updated](#) on 2015-03-12

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".

