

Certificate

The manufacturer is granted the following type test approval mark in virtue of a test report:

Category test approval mark: [pressure](#)

Technical inspection and surveillance organisation and test report: TÜV Rheinland dated 2023-03-30

Manufacturer/Distributor: [Honeywell GmbH](#)
[Hans-Klemm-Straße 5](#)
[71034 Böblingen](#)
[GERMANY](#)

Type test approval mark: [TÜV . DWFS / SDBFS . 23 - 281](#)

Design: pressurized metal bellows with switching contact
limit value adjustable, switching differential fixed or adjustable, standard or EEx de IIC T6 version

Type: [DWR...-...](#)
[Ex-DWR...-...](#)

The adjudication is made pursuant to:

- VdTÜV-Merkblatt Druck 100, edition 2017-03-15, in conjunction with TÜV-Verband Technical Leaflet General 002, edition 2022-09-20
- essential safety requirements of Directive 2014/68/EU from 15.05.2014 (Pressure Equipment Directive)
- DIN EN 12952-11, edition 2007-09
- DIN EN 12953-9, edition 2007-09

Valid until: [2027-01-31](#)

The adjudication is revocable. The previous certificate is replaced herewith.

Note: The manufacturer or importer is obliged to the competent Authorized Inspector to conduct a random check on the accessories concerning identity to the type once a year. The accessories have to be taken from the current production.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

division industry and plant engineering

www.tuev-verband.de/en