

Declaration of Conformity

We, **Honeywell International Inc.**
165 Eileen Way
P.O. Box 9035
Syosset NY U.S.A.

Declare under our sole responsibility that the product:

MODEL NUMBERS:	6148EX	6148DE	6148IT	6148NL
	6148ICON	6148PG	6148SP	6150
	6164	6164IT	6164NL	6164SP

TYPE OF EQUIPMENT: **Keypad console for Honeywell alarm/security systems**

to which this declaration relates, are in conformity with the following Directives and Standards:

Directive 89/336/EEC & 92/31/EEC, EMC Directive.

EN 61000-6-3:2001: Generic emission standard for residential, commercial, and light-industrial environments.

EN 50130-4:1995 + A1:1998	- Electromagnetic compatibility –Immunity requirements for components of fire, intruder and social alarm systems
IEC 61000-4-2:1995, +A1:1998, +A2:2001	- Electrostatic discharge immunity test
IEC 61000-4-3:1995	- Radiated, radio-frequency electromagnetic field immunity test
IEC 61000-4-4:1995	- Electrical fast transient/burst immunity test
IEC 61000-4-5:1995	- Electromagnetic Compatibility (EMC)— Surge immunity test
IEC 61000-4-6:1996	- Immunity to conducted disturbances, induced by radio-frequency fields
IEC 61000-4-11:1994	- Voltage dips, short interruptions and voltage variations immunity tests

Directive 2006/95/EC, Low Voltage Directive

IEC60950-1:2001*: Safety of information technology equipment

* when installed according to Honeywell instructions and national electrical codes

Place of issue: Syosset NY U.S.A.

Date of Issue: 4 April 2007

by


Authorized signature – Steve Amodeo

V.P. Quality Assurance

Title

Serial no. DC0068 04/2007