CSIRO Verification Services
Clayton, Victoria, Australia
+61 (0)3 9545 2777
http://www.activfire.gov.au/

Certificate of Conformity

Certificate num.	Registration date	Version Number	Version Issue date	Valid until	
afp - 2312	9-Apr-2009	11	28-Apr-2017	30-Apr-2018	Page **1** of **1**

Product designation

System Sensor, EPS120 Series, supervisory pressure switches

Agent/distributor

FireSense Pty Ltd
18-20 Brookhollow Avenue, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Registrant

System Sensor
3825 Ohio Avenue, ST CHARLES, IL., UNITED STATES, 60174

Producer

System Sensor
3825 Ohio Avenue, ST CHARLES, IL., UNITED STATES, 60174

Conformance criteria and evaluation

The System Sensor, EPS120 Series, supervisory pressure switches has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Factory Mutual - Evaluation, surveillance and approval, 'FM approval'.
2. Underwriters Laboratories - Evaluation, follow-up services and listing, 'UL listing'.
3. Underwriters Laboratories Canada - Evaluation, follow-up services and listing, 'cUL listing'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker
Executive Officer – ActivFire Scheme

© CSIRO Australia, 2017

This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time.
The validity and authenticity of this certificate can be verified by the certification register located at http://www.activfire.gov.au