



**CSIRO** Verification Services Clayton, Victoria, Australia +61(0)395452777http://www.activfire.gov.au/

# **Certificate of Conformity**

Certificate num. **Registration date** Version Valid until Number Issue date afp - 2418 30-Apr-2018 4-May-2010 10 28-Apr-2017

Page 1 of 2

# Product designation

#### InnovairFlex<sup>™</sup>, Model D2-AUS, duct sampling unit

(Refer to the Schedule/enclosures for further specified details)

#### Agent/distributor

#### Notifier Inertia

9 Columbia Way, Norwest Business Park, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

#### Registrant

System Sensor

3825 Ohio Avenue, ST CHARLES, IL., UNITED STATES, 60174

Producer

System Sensor

3825 Ohio Avenue, ST CHARLES, IL., UNITED STATES, 60174

## **Conformance criteria and evaluation**

The InnovairFlex<sup>™</sup>, Model D2-AUS, duct sampling unit has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 1603.13-1998, 'Automatic fire detection and alarm systems -Duct sampling units'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

the unit is used in conjunction with the one of the following smoke detectors. i.

- System Sensor, Model 2151BAUS, or a.
- b. System Sensor, Model 2151BPI, or
- Honeywell, Model 2600M. С
- ii. Compatibility of the fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.
- the extended air-speed operating ranges of the unit of less than 1 m/s and greater than iii. 8 m/s were have not been verified.
- operation of the unit at temperatures below -10°C has not been verified. iv.
- the unit is used in indoor dry environments. v.

(Limitations/conditions of conformance continue)

Issued by

David Whittaker Executive Officer – ActivFire Scheme



© CSIRO Australia, 2017

This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time. The validity and authenticity of this certificate can be verified by the certification register located at http://www.activfire.gov.au

Services - Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions Reference to details, limitations

This certification is issued within

the scope of CSIRO Verification

- and requirements, where documented as a schedule/enclosure with this certificate
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.



# Schedule to Certificate of Conformity

Certificate num.	Registration date		Version	Valid until	
-f- 2440		Number	Issue date	22.4	Page <b>2</b> of <b>2</b>
afp - 2418	4-May-2010	10	28-Apr-2017	30-Apr-2018	-

- vi. the unit is installed and maintained as recommended by the manufacturer.
- vii. the unit is not used with the remote test coil accessory described in the Installation Instructions.

viii. the unit is supplied with labels in accordance with the conformance criteria.

## **Producer's description**

The InnovairFlex<sup>™</sup>, Model D2-AUS, duct sampling unit includes a housing for plug-in type smoke detectors for detection of smoke in air-handling ducts.

The combination of housing and detector provided by the Model D2-AUS utilizes photoelectric technology for the detection of smoke. When sufficient smoke is sensed, an alarm signal is initiated at the compatible control and indicating equipment (CIE).

The Model D2-AUS unit consists of the following components:

- InnovairFlex Model D2-AUS DSU housing and cover, sampling tube and exhaust tube, and
- System Sensor 2151BAUS or 2151BPI, or Honeywell 2600M, conventional photoelectric smoke detector and compatible base.

The alarm state of the Model D2-AUS is indicated by the illumination of a LED fitted to the detector.

#### **Technical specification**

The following details are a representative extract of the technical specification for the InnovairFlex<sup>™</sup>, Model D2-AUS, duct sampling unit and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

#### **Evaluated components**

Product assembly designation InnovairFlex™, Model D2-AUS, duct sampling unit						
Detector (photoelectric) component designation	Base designation	Base + detector circuit type				
System Sensor, Model 2151BAUS System Sensor, Model 2151BPI Honeywell, Model 2600M	System Sensor, Model B401	Conventional				
Nominal sensitivity: Operating voltages: Quiescent current/voltage: Alarm current: Operating temperature range: Humidity range:	4.0 %obs/m 8.5 – 35 Vdc 60 mA (average), 120 mA (peak) 130 mA -10 to 70°C 0 to 93 %RH					