EC-CERTIFICATE OF CONFORMITY

1134 - CPD - 045

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Electrical automatic control and delay devices

NOTIFIER RP1r

Variants: MORLEY VSN-RP1r, ESSER ESS-RP1r and HBS HBS-RP1r

(Extinguishing panel for 1 flooding zone with microprocessor)

Fixed fire fighting systems – Components for gas extinguishing systems

placed on the market by

HONEYWELL Life Safety Iberia
Avendida Conflent, 84, Nave 23
Polygono Industrial Pomar de Dalt
ES – 08916 Badalona - BARCELONA
SPAIN

and produced in the factory

FIRE VISION TECHNOLOGY.
Laureo Miro Nr: 401 Nave 7
Polygone Industrial El Pla
ES – 08980 Sant Feliu de Llobregat
SPAIN

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body **ANPI** has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 12094-1 :2003

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on ***04-04-2008*** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly and latest on ***03-04-2012***

Brussels, the 4 of april, 2008

Ing. M. VANDENDOREN
Secrétaire Général of ANPI

This certificate and the annex may only be copied completely and without any adding.

asbl ANPI vzw,
Parc scientifique Fleming, Granbonpré 1, B–1348 Louvain-la-Neuve - Belgium
t +32 (0)10 47 52 11 - f +32 (0)10 47 52 70 Email : cert@anpi.be

ANNEX N° 1 to EC-CERTIFICATE OF CONFORMITY

1134 - CPD - 045

04.04.2008

The device NOTIFIER RP1r and variants includes also the following optional functions of the EN 12094-1 : 2003

Options with requirements	
4.17	*Delay of the extinguishing signal*
4.18	*Signal representing the flow of extinguishing agent*
4.19	*Monitoring of the status of components*
4.20	*Emergency hold device (A or B)*
4.21	*Control of flooding time*
4.23	*Manual mode only*
4.26	*Triggering signals to equipment outside the system*
4.27	*Emergency abort devices may be connected*
4.30	*Activation of the alarm devices with different signals*

Ing. M. VANDENDOREN
Secrétaire Général of ANPI

This annex may only be copied completely and without any adding and is only valid with the CE certificate of conformity : 1134 – CPD - 045

asbl ANPI vzw,
Parc scientifique Fleming, Granbonpré 1, B–1348 Louvain-la-Neuve - Belgium
t +32 (0)10 47 52 11 - f +32 (0)10 47 52 70 Email : cert@anpi.be