BRE Global

Notified Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2558

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MI-LZR-S3I High Sensitivity Point Optical Smoke Detector with Short Circuit Isolator
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Morley-IAS Fire Systems by Honeywell (Pittway Systems Technology Group (Europe) Ltd)
Via Caboto 19/3
34147 Trieste
Italy

and produced in the manufacturing plant(s):

Pittway Tecnologica Srl
Via Caboto 19/3
34147 Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors
EN 54-17:2005 - Short circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 14 March 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 14 March 2019

Date of Issue: 14 March 2019

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

© BRE Global Ltd., 2019

BRE Global Limited
Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2558

MI-LZR-S3I High Sensitivity Point Optical Smoke Detector with Short Circuit Isolator

Base:
B501AP Intelligent Sensor Base

Note:
1. Meets the requirements of EN 54-7:2000 at high sensitivity

P Halligan, Certification Manager,
On behalf of BRE Global Limited

Date of First Issue: 14 March 2019
Date of Issue: 14 March 2019
Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

© BRE Global Ltd., 2019