CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7120-0075:0199 Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: FIRE-LITE ALARMS INC.One Fire-Lite Place, Northford, CT 06410-1653

Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309

Email: Brian.Reynolds2@Honeywell.com

DESIGN: Model ACS annunciator control system. Refer to listee's data sheet for additional detailed

product description and operational considerations. Unit consists of the following modules:

ACM-16ATF Control Module ACM-32AF Control Module

ABF-1F, -1DF, -2F, -2DF, -4F Enclosures (Flush)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as an annunciator system when used in conjunction with separately listed compatible

fire alarm control units.

XLF: 7120-0028:0156

*Rev. 05-06-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2014 Listing Expires June 30, 2015

Authorized By: JAMES PARSEGIAN, Program Coordinator

Fire Engineering Division