

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3242-0075:0221 Page 1 of 1

CATEGORY: 3242 -- DUCT SMOKE DETECTOR, PHOTO. (W/ OR W/O BASE)

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Model *D355PL analog photoelectric duct smoke detector housing. Unit consists of a duct detector housing, exhaust tubes, and separately listed Fire-Lite Alarms' Model SD355 or SD355R detector heads (OSFM Listing No. 7272-0075:194). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, air velocity and UL label.

APPROVAL: Listed as conventional photoelectric duct smoke detector housing for use with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 3242-1653:0209

*Corrected 05-11-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGAN**, Program Coordinator
Fire Engineering Division