

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0075:0224 Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653  
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309  
Email: Brian.Reynolds2@Honeywell.com

**DESIGN:** Models MS-25(E) fire alarm control units. Automatic, manual, waterfowl, sprinkler supervisory, local, remote station (PPU), and central station (PPU) services. Refer to the listee's data sheet for additional detailed product description and operational considerations  
System components:  
  
BB-26; Battery Boxes  
IPDACT-2/-2UD; IP Fire Alarm Communicator  
HFS-MM; Addressable Mini-Monitor Module  
HFS-MR; Addressable Relay Module  
BB-55F; Battery Boxes  
BG-12LX; Addressable dual action manual pull station

**RATING:** 120 VAC or 230 VAC primary, 24 VDC secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units suitable for high-rise applications when used in conjunction with separately listed compatible initiating and indicating devices. This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.  
  
This control unit meets the requirements of UL Standard 864, 9th Edition.

**NOTE:** 1. For Fire Alarm Verification Feature (Delay of fire alarm), the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

**XLF:** 7165-0559:0165

06-03-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*