

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-1637:0102

Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: HONEYWELL POWER PRODUCTS 12 Clintonville Road, Northford, CT 06472
Contact: Vladimir Kireyev (203) 484-6277 Fax (203) 484-7309
Email: Vladimir.kireyev@honeywell.com

DESIGN: Models HPF24S6, HPF24S8, HPFF8, HPFF8E, HPFF8CM, HPFF8CME, HPFF12, HPFF12E, *HPFF12CM and *HPFF12CME power limited power supply/battery chargers used for supervision and expanded power driving capability of up to four Notification Appliance Circuits (FACP Fire Circuits, Signaling Devices) or resettable/non resettable outputs. Model ZNAC-4 Class A converter. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as power supply/battery chargers for use with separately listed compatible fire alarm control units.

XLF: 7315-0075:0206

*Rev. 10-20-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division