

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7770-1653:0114
CATEGORY: 7770 -- VALVES/SWITCHES

Page 1 of 1

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Models WFD20, -25, -30, -35, -40, -50, -60, -80, WFD-30-2, WFDT, WFDTH, WFDTNR, and RFDTH paddle-type waterflow indicators. *The RFDTH Series has a NEMA Type 4 enclosure rating. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	<u>Model</u>	<u>Size</u>	<u>Working Pressure</u>
	WFD20	2"	450 psig
	WFD25	2-1/2"	450 psig
	WFD30	3"	450 psig
	WFD30-2	3"	450 psig
	WFD35	3-1/2"	450 psig
	WFD40	4"	450 psig
	WFD50	5"	450 psig
	WFD60	6"	450 psig
	WFD80	8"	450 psig
	WFDT	1", 1-1/4", 1-1/2"	250 psig
	WFDTNR	1", 1-1/4", 1-1/2", 2"	250 psig
	WFDTH	1", 1-1/2"	250 psig
	RFDTH	1", 1-1/2", 2" Reliable Riser	250 psig

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as waterflow indicators for use with wet pipe fire sprinkler systems.

NOTE: Formerly 7770-1209:140

03-15-07mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division