**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION**
**OFFICE OF THE STATE FIRE MARSHAL**
**FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM**

# LISTING SERVICE



**LISTING No.** 7270-1653:0167

**CATEGORY:** 7270 -- HEAT DETECTOR

**LISTEE:** System Sensor, Unincorporated Div of Honeywell Int'l Inc.3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

**DESIGN:** Models 5601, 5601P, 5602, 5621, and 5622 combination fixed-temperature and rate-of-rise type and Models 5603, 5604, 5623, and 5624 fixed-temperature mechanical heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Models 5601, 5601P, 5603, 5621, & 5623 have a fixed temperature of 135°F.

Models 5602, 5604, 5622, & 5624 have a fixed temperature of 194°F.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, temperature/electrical rating, and UL label.

**APPROVAL:** Listed as heat detectors for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details and UL directory for dimensions .

**NOTE:** Formerly 7270-1209:227

06-20-05

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014** *Listing Expires* **June 30, 2015**

Authorized By: ***JAMES PARSEGIAN**, Program Coordinator*

*Fire Engineering Division*