



## UROX.S1059 Smoke-automatic Fire Detectors

[Page Bottom](#)

### Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)

#### FIRE-LITE ALARMS

S1059

1 FIRE-LITE PL

NORTHFORD, CT 06472 USA

Application	Type	Compatibility Restriction	Velocity		Model
			Range Min	(fpm) Max	
OAP	P	*	0	300	SD32, SD32-12, SD32T, SD32T-12, SD351, SD351T(i) SD725, SD726(h) SD729, SD800
OAP	P	**	0	3000	SD451, SD451T
OAP	I	***	0	300	CP400, CP451
OAP/RS	P	None	0	300	SD34, SD34S-6, SD34T(h), SD34ST-6(h)
OAP	I	*	0	1200	CPID
OAP	P	***	0	300	SD400, SD400T
OAP/RF	P	***	0	300	SDRF-351, -351S
OAP/RS	I	None	0	300	#
D(I)	I	None	500	3000	#
D(ST)	P	None			#
D(ST)	P or I	*	500	3500	DH23
OAP	I	***	0	1500	CP300
OAP	I	***	0	1200	CP355
OAP	P	***	0	3000	SD300, SD300T(i)
OAP/D(I)	P	***	0	4000	SD300, SD350T(h) SD355, SD355T(h)
OAP	P	*	0	4000	AD350(h), AD355(h)
OAP	I	**	0	500	CP350

Bases: CP-711, -712, -713, -714, -715.

Base Model No.	Related Detector	Control Unit Compatibility Restriction
----------------	------------------	----------------------------------------

B224BI, B224RB, B210LP,	CP350, SD350, SD350T	***
	SD355, SD355T	
B501BH, B501BHT	CP355	
B301LP, B350LP	SD351, SD351T, AD350	*
AD355	CP350, SD350, SD350T	***
B401	CP451, SD451T	***
B401B	SD451	
BLP-12-4W	—	***
BLP-12-4W	—	**
BLP-12, -12N, -12R, -12RN	—	***

			DUCT DETECTORS				
Detector Model	Principle	Application	Velocity (fpm)		Differential Between Sampling Tube (in of W6x16)		Compatible Control Unit
			Max	Min	Max	Min	
D350P,	P	D/ST	4000	500	1.4	0.03	***
D350RP							
D350PL	P	D/ST	4000	100	1.4	0.03	***
D350RPL	P	D/ST	4000	100	1.4	0.03	***

**Projected beam smoke detectors** , Model BEAM355S\*, BEAM355\*. Suitable for use in ambient temperatures of -30 C to 55 C (-22 to 131 F) with a max distance of 18 in. below the ceiling.

\*Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

\*\* -For connection to any manufacturer's Listed compatible control unit.

\*\*\* -For connection to Listed control units with which compatibility was determined by test of a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

#Model No(s). not indicated since UL Listing Mark not applied to 100 percent of production.

(a)-Includes integral audible signal.

(h)-Includes integral heat detectors

(i)-Employs auxiliary 135 F rated heat sensor.

Codes:

OAP-Open Area Protection

D(ST)-Duct Detector-Sampling Tubes

RS-Releasing Service

D(I)-Duct Detector-Installation inside duct

P-Photoelectric

I-Ion

PB-Projected Beam

[Last Updated](#) on 2007-07-13

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

