

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-0559:0155

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models IDP-Relay-6, SK-Relay-6, relay module, IDP-Control-6, SK -Control-6, supervising control module, IDP-Monitor-10, SK-Mon-10, input monitor module, IDP-Zone-6, SK-Zone-6 six zone interface module, IDP-Monitor, IDP-Minimon, IDP-Zone, SK-Monitor, SK-Minimon, SK-Zone monitor modules, IDP-Control, IDP-Relay, SK-Control, SK-Relay, control modules, IDP-Monitor-2, SK-Monitor-2, dual monitor modules, and *IDP-RELAYMON-2, *SK-RELAYMON-2 with 2 input/2 output relay modules. All devices are intended to be connected between the signaling line circuit of a compatible fire alarm control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC Primary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units.

NOTE: If an external power supply is used for Model SK-Zone-6 and IDP-Zone-6, the negative of the external power supply is referenced to the negative of the auxiliary supply of the compatible control panel. This is done in order to detect ground faults on the initiating circuit.

XLF: 7300-0028:0219

*Rev. 10-25-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division