



Product Service

CERTIFICATE

No. Z10 020160 0011 Rev. 01

Holder of Certificate: Honeywell Safety Management Systems
Burgemeester Burgerslaan 40
5245 NH Rosmalen
THE NETHERLANDS

Certification Mark:



Product: Safety Related Programmable Electronic System

Model(s): FSC Fail-Safe Controller System Family
DMR, QMR, 1oo1D, 1oo2D

Parameters: Nominal supply voltage: 24 VDC, 115/230 VAC

Tested according to: IEC 61508-1:2010 (SIL 1-3)
IEC 61508-2:2010 (SIL 1-3)
IEC 61508-3:2010 (SIL 1-3)
EN 61511-1:2017/A1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: HR90153C

Valid until: 2027-06-29

Date, 2022-06-30

(Guido Neumann)