



# Certificate of Compliance

**Certificate:** 2700972

**Master Contract:** 171882

**Project:** 70023925

**Date Issued:** May 13, 2015

**Issued to:** Honeywell Analytics Ltd.  
Hatch Pond House  
4 Stinsford Rd.  
Nuffield Estate  
Poole, Dorset, BH17 7RZ  
United Kingdom  
**Attention: Mr. Colin Hydes**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:**

*Amarta Rakshit*  
Amarta Rakshit

## **PRODUCTS**

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Touchpoint (TPPR)Pro Relay Output Module, Model ROM, permanently connected

### **Rated:**

Input: 24 Vdc Nominal (18-32Vdc), Relay Contacts: 30Vdc/250Vac, 5A

Output: 18-32Vdc, 1.5A (max), Power Consumption: 1.5Wmax (excluding auxiliary output) or 50W max (including auxiliary output)

### **Note:**

- The above model is Equipment Class III, Pollution Degree 2.
- Mode of operation: Continuous
- Environmental Conditions: Extended: -40Deg C to 70Deg C, 2000 m max (altitude), 10 to 90%RH (non-condensing)



**Certificate:** 2700972  
**Project:** 70023925

**Master Contract:** 171882  
**Date Issued:** May 13, 2015

---

**APPLICABLE REQUIREMENTS**

- CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
  
- UL Std. No. 61010-1 (2<sup>nd</sup> Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



## *Supplement to Certificate of Compliance*

**Certificate:** 2700972

**Master Contract:** 171882

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2700972	September 26, 2014	Original CSA C-US Certification according to CAN/CSA C22.2 No. 61010-1-04 / UL 61010-1, 2 <sup>nd</sup> Edition.
70023925	May 13, 2015	Report update to include Honeywell 5 U 19" Powder coated Mild Steel open frame rack unit, as an alternate configuration for module installations according to CAN/CSA C22.2 No. 61010-1-04 / UL 61010-1, 2 <sup>nd</sup> Edition.