

CERTIFICATE OF COMPLIANCE

Certificate Number 20120529 – E163168
Report Reference E163168 – 2011 October 21
Issue Date 2012 May 29
Issued to: HONEYWELL ANALYTICS INC
SUITE 100
3261 EXECUTIVE WAY
MIRAMAR, FL 33025 USA

This is to certify that representative samples of

Gas and Vapor Detection Equipment Classified for Use in Hazardous Locations Intrinsically Safe Gas Detector Series 3000 MKIII Models S3KUX3, S3KUL3 and S3KUS3 transmitters for use for use in Class I, Division 1 and 2, Groups A, B, C and D; Class II, Division 1 and 2, Groups E, F and G when connected in accordance with Control Drawing No. 3000G3303.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.



Standard(s) for Safety:

UL 913 “Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II and III, Division 1, Hazardous (Classified) Locations” and CAN/CSA C22.2 No. 157-92 “Intrinsically Safe and Non-incendive Equipment for use in Hazardous Locations.

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Classification Mark for the U.S. and Canada should be considered as being covered by UL's Classification and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Classification Mark includes: the UL in a circle symbol:  with the word “CLASSIFIED” (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL’s evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory. The UL Classification Mark for Canada includes: the UL Classification Mark for Canada:  with the word “CLASSIFIED” (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL’s evaluation of the product; and the product category name (product identity) in English, French, or English/French as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

