



Product Service

CERTIFICATE

No. Z10 16 12 96351 002

Holder of Certificate: Honeywell Analytics Limited
4 Stinsford Road
Poole
Dorset BH17 0RZ
UNITED KINGDOM

Factory(ies): 96351, 76999

Certification Mark:



Product: Safety Related Programmable Electronic System Control Module

Model(s): Touchpoint Pro Controller

Parameters: Nominal supply voltage: 24 VDC
Max. 16 input modules and 32 output modules

The report referenced below and the user documentation in the currently valid revisions are mandatory part of this certificate.

Tested according to: IEC 61508-1(ed.2) (SIL 1-2)
IEC 61508-2(ed.2) (SIL 1-2)
IEC 61508-3(ed.2) (SIL 1-2)
IEC 61508-4(ed.2) (SIL 1-2)
EN 50402:2005/A1:2008

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: HP90321C

Valid until: 2021-12-19

Date, 2016-12-20 (Matthias Ramold)

Page 1 of 1

