



# Certificate of Compliance

**Certificate:** 70025951

**Master Contract:** 171882

**Project:** 70025951

**Date Issued:** 2015-05-26

**Issued to:** Honeywell Analytics Ltd  
4 Stinsford Road  
Nuffield Estate  
Poole  
BH17 0RZ  
United Kingdom  
Attention: Mr. Colin Hydes

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:**

A handwritten signature in black ink, appearing to read 'L Pall'.

L Pall

## **PRODUCTS**

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Location

Ex nA IIC T4  
Class I, Division 2, Groups A, B, C and D

**CLASS 2258 82** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

AEx nA IIC T4  
Class I, Division 2, Groups A, B, C and D

Touchpoint Pro Ring Coupling Module (RCM), DIN rail mounted, type n and non-incendive, 18-32V dc,  
Ta = -40°C to +70°C

## **CONDITIONS OF ACCEPTABILITY**

The equipment shall be installed in an Ex e or Ex n approved enclosure, or an equivalent tool-secure enclosure approved for Div 2 use, that provides an ingress protection of at least IP54.



**Certificate:** 70025951

**Master Contract:** 171882

**Project:** 70025951

**Date Issued:** 2015-05-26

**APPLICABLE REQUIREMENTS**

CAN/CSA C22.2 No. 61010-1-12-04	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements - Third Edition
C22.2 No. 213-M1987 (R2008)	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA-C22.2 No. 60079-0:07	Explosive Atmospheres - Part 0: Equipment - General requirements
CAN/CSA-C22.2 No. 60079-15:12	Electrical apparatus for explosive gas atmospheres - Part 15: Construction, test and marking of type of protection "n" electrical apparatus
C22.2 No 152 M-1984	Combustible gas detection instruments
FM 6310 / 6320 2001	Combustible gas detectors
UL Std. No. 61010-1 (2nd Edition)	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
ANSI/ISA-12.12.01-2013	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
ANSI/UL 60079-0:2013	Explosive Atmospheres - Part 0: Equipment - General Requirements
ANSI/UL 60079-15:2013	Explosive Atmospheres - Part 15: Equipment protection by type of protection "n"