



## Midas® Sensor Cartridge Specifications

### Flammable Group (n-Octane)

### MIDAS-E-LEO

Gas Measured	N-Octane (n-C <sub>8</sub> H <sub>18</sub> )
<b>Cartridge Part Number</b>	MIDAS-E-LEO 2 year extended warranty
<b>Sensor Technology</b>	Pellistor (catalytic bead)
<b>Measuring Range</b>	n-C <sub>8</sub> H <sub>18</sub> 0 – 100%LEL
<b>Minimum Alarm 1 Set Point</b>	10%LEL
<b>Lower Detection Limit</b>	4.5%LEL
<b>Linearity</b>	< ± 10% of measured value
<b>Repeatability</b>	< ± 10% of measured value
<b>Resolution</b>	1%LEL
<b>Response Time t<sub>62.5</sub></b>	≤ 5 seconds
<b>Sensor Cartridge Life Expectancy</b>	≥ 60 months under typical application conditions
<b>Operating Temperature</b>	0°C to +40°C (32°F to 104°F)
<b>Effect of Temperature</b>	
Zero Sensitivity	< ± 1% fsd < ± 3% fsd
<b>Operating Humidity</b>	10 to 90% RH
<b>Effect of Humidity</b>	
Zero Sensitivity	< ± 1% fsd < ± 2% fsd
<b>Operating Pressure</b>	90 – 110kPa
<b>Effect of Position</b>	No effect in typical application
<b>Long Term Drift</b>	
Zero Sensitivity	< 3% fsd / year < 3% fsd / year
<b>Calibration Gas</b>	n-Butane(n-C <sub>4</sub> H <sub>10</sub> )
<b>Bump Test Gas</b>	n-Butane(n-C <sub>4</sub> H <sub>10</sub> )
<b>Warm Up Time</b>	< 30 minutes
<b>Storage Temperature</b>	+5°C to +25°C (+41°F to +77°F)

The sensor data listed is based on ideal test environment; observed performance may vary based on the actual monitoring system and the sampling conditions employed.

#### Find out more

www.honeywellanalytics.com  
 Korea Tel: +82 (0)2 6909 0300  
 Singapore Tel: +65-65803776  
 Australia Tel: +61-3-94642770  
 Japan Tel: +81-3-6730-7320  
 India Tel: +91-124 4752700

#### Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.

H\_MIDAS-E-LEO\_v2 06/22

© 2022 Honeywell Analytics

#### Cross Sensitivities

Each Midas® sensor is potentially cross sensitive to other gases and this may cause a gas reading when exposed to other gases than those originally designated. The table below presents typical readings that will be observed when a new sensor cartridge is exposed to the cross sensitive gas (or a mixture of gases containing the cross sensitive species)

Gas Measured	Chemical Formula	Concentration Applied(ppm)	Reading (%LEL)
Ammonia	NH <sub>3</sub>	10	0
Carbon Dioxide	CO <sub>2</sub>	10	0
Carbon Monoxide	CO	10	0
Chlorine	Cl <sub>2</sub>	10	0
Ethylene	C <sub>2</sub> H <sub>4</sub>	0.675%v	43
Hydrogen Chloride	HCl	10	0
Hydrogen Sulfide	H <sub>2</sub> S	10	0
Iso Propanol	C <sub>3</sub> H <sub>7</sub> OH	0.5%v	31
Methane	CH <sub>4</sub>	1.25%v	59
Nitric Oxide	NO	10	0
Nitrogen Dioxide	NO <sub>2</sub>	10	0
Sulfur Dioxide	SO <sub>2</sub>	10	0
Hydrogen	H <sub>2</sub>	1%v	67

Interference differs from cartridge to cartridge and over cell life. It is not recommended to calibrate with cross sensitivity factors. The target gas should be used for calibration.