



## Midas® Sensor Cartridge Specifications

### Phosphine (PH<sub>3</sub>)

#### MIDAS-E-PHX

Gas Measured	Phosphine (PH <sub>3</sub> )
<b>Cartridge Part Number</b>	MIDAS-E-PHX 2 year extended warranty
<b>Sensor Technology</b>	3 electrode electrochemical cell
<b>Measuring Range</b>	PH <sub>3</sub> 0 – 1200ppb
<b>Minimum Alarm 1 Set Point</b>	150ppb
<b>Lower Detection Limit</b>	135ppb
<b>Linearity</b>	< ± 20% of measured value
<b>Repeatability</b>	< ± 5% of measured value
<b>Resolution</b>	5ppb
<b>Response Time t<sub>62.5</sub></b>	≤ 5 seconds
<b>Sensor Cartridge Life Expectancy</b>	≥ 24 months under typical application conditions
<b>Operating Temperature</b>	0°C to +40°C (32°F to 104°F)
<b>Effect of Temperature</b>	
Zero	< ± 20ppb / °C
Sensitivity	< ± 1.2% of measured value / °C
<b>Operating Humidity</b>	10 to 90% RH
<b>Effect of Humidity</b>	
Zero	< ± 0.5ppb / % RH
Sensitivity	< ± 1% of measured value / % RH
<b>Operating Pressure</b>	90 – 110kPa
<b>Effect of Position</b>	No effect in typical application
<b>Long Term Drift</b>	
Zero	
Sensitivity	< ± 5% of measured value / 6 months
<b>Calibration Gas</b>	Phosphine (PH <sub>3</sub> )
<b>Bump Test Gas</b>	Phosphine (PH <sub>3</sub> )
<b>Warm Up Time</b>	< 20 minutes
<b>Storage Temperature</b>	+5°C to +25°C (+41°F to +77°F)

The sensor data listed is based on ideal test environment; observed performance may vary based on the actual monitoring system and the sampling conditions employed.

#### Cross Sensitivities

Each Midas® sensor is potentially cross sensitive to other gases and this may cause a gas reading when exposed to other gases than those originally designated. The table below presents typical readings that will be observed when a new sensor cartridge is exposed to the cross sensitive gas (or a mixture of gases containing the cross sensitive species)

Gas Measured	Chemical Formula	Concentration Applied(ppm)	Reading (ppm PH <sub>3</sub> )
Ammonia	NH <sub>3</sub>	108	<0.1
Arsine	AsH <sub>3</sub>	0.15	0.12
Carbon Dioxide	CO <sub>2</sub>	5000	0
Carbon Monoxide	CO	85	0
Chlorine	Cl <sub>2</sub>	0.85	<-0.05
Diborane	B <sub>2</sub> H <sub>6</sub>	0.2	0.01
Hydrocarbons	CH <sub>4</sub>	18000	0
Hydrogen	H <sub>2</sub>	3100	<0.05
Hydrogen Chloride	HCl	7.9	0
Hydrogen Cyanide	HCN	12.6	0.3
Hydrogen Fluoride	HF	7.2	0
Hydrogen Selenide	SeH <sub>2</sub>	0.85	0
Hydrogen Sulfide	H <sub>2</sub> S	18.2	0
Nitrogen Dioxide	NO <sub>2</sub>	10.1	-1.6
Propan-2-ol	C <sub>3</sub> H <sub>7</sub> OH	20000	<0.05
Silane	SiH <sub>4</sub>	3.5	0.4
Sulfur Dioxide	SO <sub>2</sub>	17.8	0

Interference differs from cartridge to cartridge and over cell life. It is not recommended to calibrate with cross sensitivity factors. The target gas should be used for calibration.

#### Find out more

www.honeywellanalytics.com  
 Korea Tel: +82 (0)2 6909 0300  
 Singapore Tel: +65-65803776  
 Australia Tel: +61-3-94642770  
 Japan Tel: +81-3-6730-7320  
 India Tel: +91-124 4752700

#### Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.