



Product Service

# CERTIFICATE

No. Z10 16 12 96351 002

**Holder of Certificate:** Honeywell Analytics Limited4 Stinsford Road  
Poole  
Dorset BH17 0RZ  
UNITED KINGDOM**Factory(ies):** 96351, 76999**Certification Mark:****Product:** Safety Related Programmable Electronic System Control Module**Model(s):** Touchpoint Pro Controller**Parameters:** Nominal supply voltage: 24 VDC  
Max. 16 input modules and 32 output modules

The report referenced below and the user documentation in the currently valid revisions are mandatory part of this certificate.

**Tested according to:** IEC 61508-1(ed.2) (SIL 1-2)  
IEC 61508-2(ed.2) (SIL 1-2)  
IEC 61508-3(ed.2) (SIL 1-2)  
IEC 61508-4(ed.2) (SIL 1-2)  
EN 50402:2005/A1:2008

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** HP90321C**Valid until:** 2021-12-19**Date,** 2016-12-20 ( Matthias Ramold )

Page 1 of 1

