


Technical Note

Vertex Series Cabinet Filter Usage

1998-1047 Rev 1 11/23

The Vertex Series cabinets are designed to have a filter installed in front of the pump fans/door to reduce the amount of dust and debris entering the cabinet and potentially reduce the cooling circulation inside the cabinet.

While Honeywell recommends using the filter in environments where dust is present, the use of this filter is at the user's discretion. *Should the decision be made to remove the cabinet filter, additional cleaning of the cabinet and pump fans may increase in order to maintain the cabinet cooling properly.



^{*}Removal of the Cabinet Filter will not void the product warranty against material defects and workmanship as described in the product manual.



Technical Note

Find out more:

https://sps.honeywell.com/us/en/products/safety/gas-and-flame-detection

Contact Honeywell Analytics:

Europe, Middle East, Africa

Life Safety Distribution GmbH Javastrasse 2 8604 Hegnau Switzerland

Tel: +41 (0)44 943 4300 Fax: +41 (0)44 943 4398 gasdetection@honeywell.com

Customer Service:

Tel: 00800 333 222 44 (Freephone number)
Tel: +41 44 943 4380 (Alternative number)
Fax: 00800 333 222 55

Middle East Tel: +971 4 450 5800 (Fixed Gas Detection) Middle East Tel: +971 4 450 5852 (Portable Gas Detection)

Americas

Honeywell Analytics Distribution Inc. 405 Barclay Blvd. Lincolnshire, IL 60069 USA

Tel: +1 847 955 8200 Toll free: +1 800 538 0363

Fax: +1 847 955 8210 detectgas@honeywell.com

RAE Systems by Honeywell Phone: 408.952.8200 Toll Free: 1.888.723.4800 Fax: 408.952.8480

Asia Pacific

Honeywell Industrial Safety
7F SangAm IT Tower,
434, Worldcupbuk-ro, Mapo-gu,
Seoul 03922,
Korea
Tel: +82 (0) 2 6909 0300
Fax: +82 (0) 2 2025 0328
India Tel: +91 124 4752700
China Tel: +86 10 5885 8788 3000
analytics.ap@honeywell.com

Technical Support

EMEA: gastechsupportemea@honeywell.com
Americas: is.gas.techsupport@honeywell.com
AP: gas.techsupport.apaci@honeywell.com
LATAM: SoporteTecnico.HGAS@Honeywell.com
Brazil: SuporteTecnico.HGAS@Honeywell.com

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions.

Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards and guidelines. This publication is not intended to form the basis of a contract and the company reserves the right to amend the design and specification without notice.