


**Product Family**  
**Honeywell Eyewash Cleaning Kit**

For use with all tank-type, eyewash stations. Allows thorough eyewash device cleaning. Use prior to refilling to remove contamination to interior tank walls.

**Product Numbers & Ordering Information**

Product Numbers	Details
 32-000518-0000	<b>Cleaning Kit</b> Cleaning Kit for use with all tank-style eyewash stations (Fendall Porta Stream I, II, III) Case Qty: 1 Case Dimensions: 6" x 2" x 40" Case Weight (lbs): 2

**Packaging Information**

Case Dimensions: 36" x 6" x 3", Case Weight: 2 lbs Not Required for Fendall 2000 or Fendall Pure Flow 1000

**Overview**

**Key Features**

Helps remove contaminants from tank interior.

**Hazards**

- Airborne Particulates
- Biohazard
- Chemical
- Contamination
- Gas, Vapors, Smoke
- Splash

**Historical Brand**

Fend-all

**Warranty Information**

LIMITED WARRANTY. Except for any warranty for a particular product or part specifically stated in our product literature, we warrant all goods sold under this Agreement against defects in materials and workmanship for one year from shipment. In the event of such defects, we will, at our sole option and as your exclusive remedy, repair or replace the defective product without charge, or refund the price you have paid. In order for this warranty to be effective, you must notify us within 15 days of discovery of the defect. You must return the defective product to us within the warranty period, properly packaged and with insurance and transportation costs prepaid. We will reship the product to you at our expense in the United States. This warranty does not cover defects which we determine are because of accident, alteration, modification, negligence, misuse, abuse, failure to perform adequate maintenance, normal wear and tear and normal maintenance. WE MAKE NO OTHER WARRANTIES, EXPRESS OR IMPLIED, AND WE SPECIFICALLY EXCLUDE ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. NO PERSON IS AUTHORIZED TO EXTEND ADDITIONAL WARRANTIES ON OUR BEHALF.

## Specifications

### Compatible with

- For use with all tank-type, eyewash stations.

### Uses

- Allows thorough eyewash device cleaning. Clean prior to refilling, to remove contamination.

## Literature & Documents

### Label 32-000518 Universal Eyewash Cleaning Concentrate\_French

[http://www.honeywellsafety.com/Supplementary/Documents\\_and\\_Downloads/Eye\\_and\\_Face\\_Protection/Emergency\\_Eyewash/20434/1033.aspx](http://www.honeywellsafety.com/Supplementary/Documents_and_Downloads/Eye_and_Face_Protection/Emergency_Eyewash/20434/1033.aspx)

UNIVERSAL EYEWASH CLEANING CONCENTRATE DTERGENT/DSINFECTANT VIRUCIDE • DODORISANT INGRDIENTS  
ACTIFS : Chlorures dammonium n-Alkyl (60% C14, 30% C16, 5% C12, 5% C18) dimthylbenzylque .....  
2,25 % Chlorures dammonium n-Alkyl (68% C12, 32% C14) dimthylthylbenzylque ..... 2,25 % I

### Label 32-000518 Universal Eyewash Cleaning Concentrate\_Spanish

[http://www.honeywellsafety.com/Supplementary/Documents\\_and\\_Downloads/Eye\\_and\\_Face\\_Protection/Emergency\\_Eyewash/20435/1033.aspx](http://www.honeywellsafety.com/Supplementary/Documents_and_Downloads/Eye_and_Face_Protection/Emergency_Eyewash/20435/1033.aspx)

UNIVERSAL EYEWASH CLEANING CONCENTRATE DETERGENTE /DESINFECTANTE VIRUCIDA • DESODORIZANTE  
INGREDIENTES ACTIVOS: n-alquilo (60% C14, 30% C16, 5% C12, 5% C18) dimetilo benzilo cloruros de  
amonio..... 2.25% n-alquilo (68% C12, 32% C14) dimetilo etilobenzilo cloruros de amonio.....

### Label 32-000518 Universal Eyewash Cleaning Kit Instructions\_English\_Spanish\_French\_US

[http://www.honeywellsafety.com/Supplementary/Documents\\_and\\_Downloads/Eye\\_and\\_Face\\_Protection/Emergency\\_Eyewash/20436/1033.aspx](http://www.honeywellsafety.com/Supplementary/Documents_and_Downloads/Eye_and_Face_Protection/Emergency_Eyewash/20436/1033.aspx)

Universal Eyewash Cleaning Kit Instructions for Use 1. Drain the eyewash station of any flushing fluid by activating the unit. Open the fill cap and remove any remaining solution by inverting the unit. 2. Rinse the unit with clean tap water, agitate thoroughly, then invert the station until the water is drained. 3. Aft

## Training & Proper Use

Directions provided for use

## Technical Support

US Sperian Customer Care: 866-257-7374