



Certificate of Compliance

Certificate: 2701312

Master Contract: 171882

Project: 70023926

Date Issued: May 13, 2015

Issued to: Honeywell Analytics Ltd.
Hatch Pond House
4 Stinsford Rd.
Nuffield Estate
Poole, Dorset, BH17 7RZ
United Kingdom
Attention: Mr. Colin Hydes

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Amarta Rakshit
Amarta Rakshit

PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Touchpoint Pro (TPPR) Ring Coupling Module, Model RCM, permanently connected

Rated:

Input : 24 V dc nominal(18-32Vdc), Power Consumption : 1.0 W max

Note:

- a. The above model is Equipment Class III, Pollution Degree 2.
- b. Mode of operation: Continuous
- c. Environmental Conditions: Extended: -40 Deg C to 70 Deg C, 2000 m max (altitude), 10 to 90%RH (non-Condensing)



Certificate: 2701312
Project: 70023926

Master Contract: 171882
Date Issued: May 13, 2015

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
- UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 2701312

Master Contract: 171882

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2701312	September 26, 2014	Original CSA C-US Certification according to CAN/CSA C22.2 No. 61010-1-04 / UL 61010-1, 2 nd Edition.
70023926	May 13, 2015	Report update to include Honeywell 5 U 19" Powder coated Mild Steel open frame rack unit as an alternate configuration for module installation according to CAN/CSA C22.2 No. 61010-1-04 / UL 61010-1, 2 nd Edition.