



Product Service

CERTIFICATE

No. Z10 096351 0005 Rev. 00

Holder of Certificate: Honeywell Analytics Limited
4 Stinsford Road
Poole, Dorset BH17 0RZ
UNITED KINGDOM

Certification Mark:



Product: Safety Related Programmable Electronic System
Control Module

Model(s): Touchpoint Pro Controller

Parameters: Nominal supply voltage: 24 VDC
Max. 16 input modules and 32 output modules

The report referenced below and the user documentation in the currently valid revisions are mandatory part of this certificate.

Tested according to: IEC 61508-1:2010 (SIL1-2)
IEC 61508-2:2010 (SIL1-2)
IEC 61508-3:2010 (SIL1-2)
IEC 61508-4:2010 (SIL1-2)
EN 50402:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: HP90321C

Valid until: 2027-02-21

Date, 2022-02-22

(Matthias Ramold)