



Certificate of Compliance

Certificate: 70038409

Master Contract: 171882

Project: 70038409

Date Issued: August 03, 2015

Issued to: Honeywell Analytics Ltd.
Hatch Pond House
4 Stinsford Rd.
Nuffield Estate
Poole, Dorset, BH17 7RZ
United Kingdom

Attention: Mr. Colin Hydes

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Amarta Rakshit
Amarta Rakshit

PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Touchpoint Pro Remote Wall Mount enclosure system Z2/Div 2, permanently connected

Rated: 18-32 Vdc, 480W max

Note:

- The above model is Equipment Class 1 (grounded), Pollution Degree 2
- Mode of operation: Continuous
- Environmental Conditions: Extended: -40 Deg C to +55 Deg C max, 2000 m max(Altitude), 0 – 100% RH (condensing)
- W (max) will be dependent on number of modules and configuration.
- Enclosure also confirms to IP66, Type 4, 4X ratings thus making it suitable to pollution degree 4 environment



Certificate: 70038409

Project: 70038409

Master Contract: 171882

Date Issued: August 03, 2015

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
- UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

CONDITIONS OF ACCEPTABILITY

Equipment is to be installed by manufacturer trained personnel or competent person trained in accordance with manufacturer installation instructions.



Supplement to Certificate of Compliance

Certificate: 70038409

Master Contract: 171882

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70038409	August 03, 2015	Original CSA C-US Certification according to CAN/CSA C22.2 No. 61010-1-04 / UL 61010-1, 2 nd Edition.