



## CERTIFICATE OF COMPLIANCE

This is to certify that the following Fendall brand eyewash devices comply with the requirements of the ANSI Z358.1 Standard for Emergency Shower and Eyewash Equipment.

Fendall 2000™

Fendall Pure Flow 1000®

Fendall Porta Stream® II

Fendall Porta Stream® III

- ANSI Z358.1 states that plumbed and self-contained eyewash equipment shall be capable of delivering flushing fluid to the eyes not less than 1.5 liters (0.4 gpm) per minute for 15 minutes.
- A means shall be provided to ensure that a controlled flow of flushing fluid is provided to both eyes simultaneously at a velocity low enough to be non-injurious to the user.
- The eyewash unit shall be designed to provide enough room to allow the eyelids to be held open with the hands while the eyes are in the flushing fluid stream.

A handwritten signature in black ink, reading "John Peipock", is written over a horizontal line.

John Peipock  
QA Manager/Certified Six Sigma BB