

## Midas<sup>®</sup> SENSOR CARTRIDGE SPECIFICATIONS

### Halogen Group (Br<sub>2</sub> ClO<sub>2</sub>) MIDAS-S-BR2, MIDAS-E-BR2



Gas Measured	Bromine (Br <sub>2</sub> )
<b>Cartridge Part Number</b>	MIDAS-S-BR2 1 year standard warranty MIDAS-E-BR2 2 year extended warranty
<b>Sensor Technology</b>	3 electrode electrochemical cell
<b>Measuring range (ppm)</b>	Br <sub>2</sub> 0 – 0.4ppm
<b>Minimum Alarm 1 Set Point</b>	0.05ppm
<b>Repeatability</b>	< ± 5% of measured value
<b>Linearity</b>	< ± 2% of measured value
<b>Response Time t<sub>92.5</sub></b>	< 8 seconds
<b>Sensor Cartridge Life Expectancy</b>	≥ 24 months under typical application conditions
<b>Operating Temperature</b>	0°C to +40°C (32°F to 104°F)
<b>Effect of Temperature</b>	No effect (0°C to 20°C) Zero < ± 0.002ppm / °C (20°C to 40°C) Sensitivity < ± 2 % of measured value / °C
<b>Operating Humidity (continuous)</b>	15 – 90% rH
<b>Effect of Humidity</b>	Zero < 0.003ppm / % rH Sensitivity ± 0.5% of measured value / % rH
<b>Operating Pressure</b>	70 – 110kPa
<b>Effect of Position</b>	No effect in typical application
<b>Long Term Drift</b>	Zero ± 2 ppm / year Sensitivity < 5% of measured value / year
<b>Calibration Gas</b>	Chlorine (Cl <sub>2</sub> )
<b>Challenge Gas (Bump Test)</b>	Chlorine (Cl <sub>2</sub> )
<b>Warm Up Time</b>	< 20 minutes
<b>Storage Temperature</b>	+5°C to +25°C (+41° to +77°F)

The sensor data listed is based on ideal test environment; observed performance may vary based on the actual monitoring system and the sampling conditions employed

#### Other Detectable Gases

The following additional gases can be detected with this sensor cartridge. Sensor performance and characteristics will be representative of the data as tabulated above. Consult the Technical Manual to set up the Midas<sup>®</sup> transmitter with the designated identification code for each of the following gas types.

Detectable Gas	Chemical Formula	Measuring Range
Chlorine Dioxide	ClO <sub>2</sub>	0 – 0.4ppm

#### Cross Sensitivities

Each Midas<sup>®</sup> sensor is potentially cross sensitive to other gases and this may cause a gas reading when exposed to other gases than those originally designated. The table below presents typical readings that will be observed when a new sensor cartridge is exposed to the cross sensitive gas (or a mixture of gases containing the cross sensitive species).

Gas / Vapor	Chemical Formula	Concentration applied (ppm)	Reading (ppm ClO <sub>2</sub> )
Ammonia	NH <sub>3</sub>	50	-1.9
Carbon Dioxide	CO <sub>2</sub>	2000	0
Hydrogen Chloride	HCl	3	0.4
Hydrogen Sulphide	H <sub>2</sub> S	25	-16.3
Nitrogen Dioxide	NO <sub>2</sub>	16	0.4 (transient)
Sulphur Dioxide	SO <sub>2</sub>	2	0.36

#### Find out more

[www.honeywellanalytics.com](http://www.honeywellanalytics.com)

Toll-free: 800.538.0363

#### Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.