

## Midas<sup>®</sup> SENSOR CARTRIDGE SPECIFICATIONS

### Phosphine (PH<sub>3</sub>) MIDAS-S-PH3, MIDAS-E-PH3



Gas Measured	Phosphine (PH <sub>3</sub> )
<b>Cartridge Part Number</b>	MIDAS-S-PH3 1 year standard warranty MIDAS-E-PH3 2 year extended warranty
<b>Sensor Technology</b>	3 electrode electrochemical cell
<b>Measuring Range (ppm)</b>	PH <sub>3</sub> 0 – 1.2ppm
<b>Minimum Alarm 1 Set Point</b>	0.15ppm
<b>Repeatability</b>	< ± 5% of measured value
<b>Linearity</b>	< ± 10% of measured value
<b>Response Time</b> <sub>t62.5</sub>	≤ 2 seconds
<b>Sensor Cartridge Life Expectancy</b>	≥ 24 months under typical application conditions
<b>Operating Temperature</b>	0°C to +40°C (32°F to 104°F)
<b>Effect of Temperature</b>	< ± 0.001ppm / °C (0°C to 20°C) < ± 0.003ppm / °C (20°C to 40°C)
<b>Zero Sensitivity</b>	< ± 0.6% of measured value / °C
<b>Operating Humidity (continuous)</b>	10 – 90% rH
<b>Effect of Humidity</b>	
<b>Zero Sensitivity</b>	< 0.0015ppm / % rH < ± 1% of measured value / % rH
<b>Operating Pressure</b>	90 – 110kPa
<b>Effect of Position</b>	No effect in typical application
<b>Long Term Drift</b>	
<b>Zero Sensitivity</b>	< ± 0.02ppm / year < ± 10% of measured value / year
<b>Calibration Gas</b>	Phosphine (PH <sub>3</sub> )
<b>Challenge Gas (Bump Test)</b>	Phosphine (PH <sub>3</sub> )
<b>Warm Up Time</b>	< 20 minutes
<b>Storage Temperature</b>	+5°C to +25°C (+41°F to +77°F)

The sensor data listed is based on ideal test environment; observed performance may vary based on the actual monitoring system and the sampling conditions employed

#### Cross Sensitivities

Each Midas<sup>®</sup> sensor is potentially cross sensitive to other gases and this may cause a gas reading when exposed to other gases than those originally designated. The table below presents typical readings that will be observed when a new sensor cartridge is exposed to the cross sensitive gas (or a mixture of gases containing the cross sensitive species).

Gas / Vapor	Chemical Formula	Concentration Applied (ppm)	Reading (ppm PH <sub>3</sub> )
<b>Ammonia</b>	NH <sub>3</sub>	100	1.05
<b>Arsine</b>	AsH <sub>3</sub>	1	0.68
<b>Carbon Monoxide</b>	CO	2000	< 0.01
<b>Chlorine</b>	Cl <sub>2</sub>	1	- 0.07
<b>Diborane</b>	B <sub>2</sub> H <sub>6</sub>	1	0.45
<b>Ethanol</b>	C <sub>2</sub> H <sub>5</sub> OH	2000	< 0.01
<b>Germane</b>	GeH <sub>4</sub>	1	0.45
<b>Hydrogen</b>	H <sub>2</sub>	5000	< 0.01
<b>Hydrogen Chloride</b>	HCl	10	< 0.01
<b>Hydrogen Fluoride</b>	HF	10	< 0.01
<b>Hydrogen Sulphide</b>	H <sub>2</sub> S	0.5	0.07
<b>Iso Propanol</b>	C <sub>3</sub> H <sub>7</sub> OH	2000	0
<b>Nitrogen Dioxide</b>	NO <sub>2</sub>	8	- 0.86
<b>Silane</b>	SiH <sub>4</sub>	1	0.36
<b>Sulphur Dioxide</b>	SO <sub>2</sub>	50	0.55

#### Find out more

[www.honeywellanalytics.com](http://www.honeywellanalytics.com)

Toll-free: 800.538.0363

#### Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.