

E³Point[®] SPECIFICATIONS

Toxic and Combustible Gas Detector Network Platform (BACnet MS-TP, Modbus)



General Specifications					
Uses	Wall or duct-mounted, BAS or controller networkable gas detector for monitoring carbon monoxide (CO), nitrogen dioxide (NO ₂), hydrogen sulfide (H ₂ S), oxygen (O ₂), methane (CH ₄), hydrogen (H ₂) and propane (C ₃ H ₈).				
Size	20.56 x 14.90 x 6.72cm (8.09 x 5.87 x 2.65") (H x W x D)				
Power Requirement	24 Vac nominal (17-27Vac), 50/60 Hz, 0.35 A; 24 Vdc nominal (20-38Vdc)				
Relay Output	1 DPDT relay, 5A @ 250Vac; 5A @ 30Vdc				
Communications	RS485 Modbus; BACnet MS-TP master				
Operating Environment	Commercial, Indoor, Extreme Temperature Environments				
Operating Temperature	H ₂ S, NO ₂ , O ₂ , CH ₄ , H ₂ , C ₃ H ₈ : -40 to 50°C (-40 to 122°F) CO: -20 to 50°C (-4 to 122°F)				
Response Time	T90 < 50 seconds With ECLAB T90 < 240 seconds				
Display	8 character, 2 line backlit LCD				
Visual Indicators	Green LED: Power Amber LED 1: Alarm/Fault Amber LED 2: Alarm/Fault				
Audible Alarm	>85 dBA at 3 m (10 ft)				
Accuracy	± 3% of full scale @ 25 C				
Gases Detected, Detection Ranges and Alarm Levels					
Gas	Resolution	Range	Alarm A	Alarm B	Alarm C
CO (Carbon monoxide)	1 ppm	0-250 ppm	25 ppm	100 ppm	225 ppm
H₂S (Hydrogen sulfide)	0.1 ppm	0-50 ppm	10 ppm	15 ppm	20 ppms
NO₂ (Nitrogen dioxide)	0.1 ppm	0-10 ppm	0.7 ppm	2 ppm	9 ppm
O₂ (Oxygen)	0.1% vol.	0-25% vol.	19.5% vol.	22% vol.	22.5% vol.
H₂ (Hydrogen)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
CH₄ (Methane)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
C₃H₈ (Propane)	0.5% LEL	0-100% LEL	25% LEL	50% LEL	90% LEL
Enclosure					
	Polycarbonate				
Certification					
	CSA C22.2 No. 61010-1, UL 61010-1; FCC part 15; ICES-003 issue 4; ISO 9001-2008				

Find out more

www.honeywellanalytics.com

Toll free: 1 800 563 2967

Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.