

## MICRO SWITCH Cable-Pull Safety Switches



#### DESCRIPTION

MICRO SWITCH CPS Series Cable-Pull Safety Switches provide a readily accessible emergency stop signal, a cost-effective means compared to using multiple emergency stop push-buttons. The CPS Series Cable Pull Safety Switch's internal mechanism latches on both slackened cable (push) and pulled cable.

The 1CPS is intended for use in applications where the cable span is 76 m [250 ft] or shorter. It is an economical solution for shorter runs or zone protection typical to automated systems. The 2CPS Series is intended for use in very long cable runs of 152 m [500 ft] or shorter, such as long conveyor lines found in warehouses.

A line in the midpoint of the cable tension window indicates proper cable tension, providing easy set-up. The direct opening switch contacts are held closed when the actuating cable is under proper tension and the reset knob is set to the RUN position. When the actuating cable is pulled, slackened, or broken, a cam positively opens the NC (Normally Closed) switch contacts. The snap-action operation causes the switch contacts to change state and mechanically latch almost simultaneously when the cable is pulled, slackened, or broken. The NC switch contacts remain open until the CPS is reset by properly tensioning the cable and manually rotating the reset knob.

The optional "Easy Start" threaded bushing enables quick alignment of the mounting nut to minimize any cross threading. The panel stand-off with O-ring feature available on some listings eliminates the need for behind-the-panel hardware, provides a uniform panel height and a panel-to-cover seal.

#### **FEATURES**

- Direct opening action of NC (Normally Closed) contacts
- 2CPS: 2NO/2NC, 1NO/3NC, or 4NC contact configurations
- 1CPS: 1NO/1NC, 2NO/2NC, 1NO/3NC, or 4NC contact configurations
- Typical cable span of 76 m [250 ft] in an environment with a temperature change of ±17°C [±30°F]. Longer spans are possible depending upon temperature change and installation
- Choice of three actuator configurations (2CPS)
- Removable contact block version available (2CPS)
- J-hook turnbuckle included (2CPS)
- E-stop option (1CPS)
- Low profile reset and new indicator options (2CPS)
- Large wiring cavity with straight-through wiring
- Models avaliable without broken cable, slack-cable detection
- 24 Vdc or 120 Vac bright, multi-cluster high-intensity LED status indicator light available on 2CPS. Single LED on 1CPS. Low profile LED (2CPS) and emergency stop button (1CPS) options also offered
- Gold-plated contacts are standard on 2CPS, available on 1CPS
- Electrostatic, epoxy-coated, die-cast zinc housing
- Optional hardware packets available

## DIFFERENTIATION

• Internal mechanism latches on both slackened cable (push) and pulled cable

## **VALUE TO CUSTOMERS**

- Cost-effective means of providing an emergency stop signal compared to multiple emergency stop push buttons
- Capability enhances productivity by minimizing nuisance stops due to variations in temperature, stretch of cable over time, or other application variables
- Direct opening of normally closed contacts when cable is actuated

## **APPLICATIONS**

- Long conveyor systems found in warehouses and distribution centers
- Conveyor systems with a high amount of vibration
- Conveyor systems that experience wide temperature swings
- Long conveyor systems where easy-through wiring, or highly visible trip status, is required
- Perimeter guarding in hose-down conditions
- Packaging equipment
- Assembly lines

#### PORTFOLIO

The MICRO SWITCH CPS series is the largest switch in Honeywell's MICRO SWITCH line of safety switches. To view the entire product portfolio, click here.

Honeywell

TABLE 1. SPECIFICATIONS	
Characteristic	Parameter
Description	Cable-pull safety switches
Switching options	1NO/1NC direct acting 2NO/2NC direct acting 1NO/3NC direct acting 4NC direct acting
Sealing	IP67, NEMA 1, 4, 12, 13
Contacts	Silver, gold plated over silver
Conduit/connectors	1/2 NPT, PG 13.5, 20 mm, PF 1/2; Brad Harrison 10-pin conductor
Force to maintain Actuation shaft	1CPS & 2CPS: 25 lb*
Actuation shaft operating force	1CPS & 2CPS: 40 lb*
Operating temperature	-40°C to 80°C [-40°F to 176°F]
Storage temperature	1CPS: -40°C to 85°C [-40°F to 185°F]
Mechanical endurance	1 million operations
Rated thermal current ( $I_{th}$ )	10 A
Rated impulse withstand (U <sub>imp</sub> )	2500 V
Rated insulation voltage (U <sub>i</sub> )	300 V
Useable gold-plated current	1 mA to 50 mA, 60 Vdc max./125 Vdc max.
Pollution degree	3
<b>Conditional short circuit current</b>	1000 A
Short circuit protective device (Type/maximum rating)	Class J fuse (10 A/600 V)
Shock	15 g per IEC 68-2-27
Vibration	10 Hz to 500 Hz, 5 g per IEC 68-2-6
Approvals	UL, CSA, CE, UKCA, SIL
Standards	<ul> <li>UL Listed per File E37138 against UL508</li> <li>CSA Certified per File 57323 against CSA C22.2 No. 14</li> <li>CE, UKCA mark: The CPS complies with Low Voltage Directive 2014/30/EU; Machinery Directive 2006/42/EC only as the directives relate to the components being used in a safety function; EN 60947-1; EN 60947-5-1; EN 60947-5-5</li> <li>SIL: MCTF (Mechanical Life): &gt;1,000,000 cycles with single-sided confidence limit of 100 %. MCTF (Electrical Life): &gt;25,000 cycles with single-sided confidence limit of 87.5 %. Highest SIL Capability: SIL3 (HFT:1), IEC 61508-2: 2010. Proof Test Interval: 1 Year</li> </ul>
	Proof lest interval: 1 Year

\* Incline measures and not typical for manual trip

TABLE 2. ELECTRICAL RATINGS						
ac		dc	dc			
A300 Ue	AC15 le	Q300 Ue	DC13 le			
Volts	Amps	Volts	Amps			
_	_	24	2.8			
120	6	125	0.55			
240	3	250	0.27			
lth = 10 A						

#### Figure 1. 1CPS Product Nomenclature and Order Guide



NOTE: Not all combinations of model code are available.

Please contact your Honeywell provider/representative for assistance.

#### Figure 2. 2CPS Product Nomenclature and Order Guide



<sup>1</sup> Not valid on 4NC switches

# TEMPERATURE-SPAN DISTANCE APPLICATION INFORMATION

Cable-pull switches featuring broken cable detection require pre-tensioning in order to enable the RUN condition.

The relative expansion or contraction of the steel actuating cable when the ambient temperature increases or decreases must be taken into account when pre-tensioning a cable pull switch.

The change in cable length with change in temperature can cause significant nuisance shut downs on longer runs.

Install the system when the temperature is at the mid point of the extremes. If a warehouse has a low temperature of  $15.6^{\circ}C$  [60°F] and a high of  $32.2^{\circ}C$  [90°F], set up the system at the midpoint  $23.9^{\circ}C$  [75°F].

Use an endspring or another CPS at the opposite end of the cable span to double the temperature tolerance and to meet the requirements of EN 418.

# Figure 3. Total Temperature Variation vs. Cable Span Distance



A = Total temperature variation

- B = Setup point Ideally at middle of temperature extremes
- C = Cable Pull Switch usable temperature span without endspring or second CPS

 $\mathsf{D}=\mathsf{Cable}\;\mathsf{Pull}\;\mathsf{Switch}\;\mathsf{usable}\;\mathsf{temperature}\;\mathsf{span}\;\mathsf{with}\;\mathsf{endspring}\;\mathsf{or}\;\mathsf{second}\;\mathsf{CPS}$ 

E = Cable span distance

#### Table 3. Circuitry Charts

Circuitry	Chart
1NO/1NC	$ \begin{array}{c} \textcircled{\begin{array}{c} 21 \\ 22 \\ 13 \\ 14 \end{array}} $
2NO/2NC	$ \begin{array}{c} \textcircled{blue}{21} & \overbrace{22} & \textcircled{blue}{21} & \overbrace{22} \\ \hline 13 & 14 & 13 & 14 \end{array} $
1NO/3NC	$ \begin{array}{c}                                     $
4NC	$ \begin{array}{c}                                     $

#### **Table 4. 1CPS Contact Blocks**



Table 5. 2CPS Contact Blocks



Bar Chart

Contact ClosedContact Open

#### TABLE 6. 1CPS WITH BROKEN CABLE DETECTION ORDER GUIDE

Catalog	Conduit	Switching
Listing	Conduit	Switching
10001		1.N.O. (1.N.O.
1CPSA1	1/2 in NPT	1NO/1NC
1CPSA1A	1/2 in NPT	1NO/1NC
1CPSA1B	1/2 in NPT	1NO/1NC
1CPSA5	1/2 in NPT	1NO/1NC
1CPSC1	20 mm	1NO/1NC
1CPSC1A	20 mm	1NO/1NC
1CPSC5	20 mm	1NO/1NC
1CPSA2	1/2 in NPT	2NO/2NC
1CPSA2A	1/2 in NPT	2NO/2NC
1CPSA2B	1/2 in NPT	2NO/2NC
1CPSA6	1/2 in NPT	2NO/2NC
1CPSA6A	1/2 in NPT	2NO/2NC
1CPSA6B	1/2 in NPT	2NO/2NC
1CPSC2	20 mm	2NO/2NC
1CPSC2A	20 mm	2NO/2NC
1CPSC2B	20 mm	2NO/2NC
1CPSC6	20 mm	2NO/2NC
1CPSC6A	20 mm	2NO/2NC
1CPSA3	1/2 in NPT	1NO/3NC
1CPSA3A	1/2 in NPT	1NO/3NC
1CPSA3A-F01	1/2 in NPT	1NO/3NC
1CPSA3A-F02	1/2 in NPT	1NO/3NC
1CPSA3B	1/2 in NPT	1NO/3NC
1CPSA7	1/2 in NPT	1NO/3NC
1CPSC3	20 mm	1N0/3NC
1CPSC3A	20 mm	1NO/3NC
1CPSC7	20 mm	1N0/3NC
1CPSA4	1/2 in NPT	4NC
1CPSA4B	1/2 in NPT	4NC
1CPSA8	1/2 in NPT	4NC
1CPSC4	20 mm	4NC

1CPSC8

20 mm

4NC









Contact Material	Pilot Light 24 Vdc LED	Pilot Light 120 Vac LED	Notes
silver alloy			-
silver alloy	$\checkmark$		-
silver alloy		$\checkmark$	-
gold-plated			-
silver alloy			-
silver alloy	$\checkmark$		-
gold-plated			-
silver alloy			-
silver alloy	$\checkmark$		-
silver alloy		$\checkmark$	-
gold-plated			-
gold-plated	$\checkmark$		-
gold-plated		$\checkmark$	-
silver alloy			-
silver alloy	$\checkmark$		-
silver alloy		$\checkmark$	-
gold-plated			-
gold-plated	$\checkmark$		-
silver alloy			-
silver alloy	$\checkmark$		-
silver alloy	V		10-pin Brad Harrison connector; actuator to right
silver alloy	√		10-pin Brad Harrison connector; actuator to left
silver alloy		$\checkmark$	-
gold-plated			-
silver alloy			-
silver alloy	✓		-
gold-plated			-
silver alloy			-
silver alloy		$\checkmark$	-
gold-plated			-
silver alloy			-
gold-plated			-

TABLE TABLE 7	TABLE TABLE 7. 1CPS WITHOUT BROKEN CABLE DETECTION ORDER GUIDE						
Catalog Listing	Conduit	Switching	Bar Chart Contact Closed Contact Open	Contact Material	Pilot Light 24 Vdc LED	Pilot Light 120 Vac LED	Notes
1CPSA1-N	1/2 in NPT	1NO/1NC	⊖ 9.9 [0.39]	silver alloy			-
1CPSA1A-N	1/2 in NPT	1NO/1NC	7,9 12,7 0 [0.31] [0.5] Left 21-22 Switch 13-14	silver alloy	✓		-
1CPSA1B-N	1/2 in NPT	1NO/1NC	Pulled cable	silver alloy		√	-
1CPSA2-N	1/2 in NPT	2NO/2NC	9,9 [0.39] 7,9 [0.31] [0.5] Left 21-22	silver alloy			-
1CPSA2B-N	1/2 in NPT	2NO/2NC	Switch 13-14 Right 21-22 Switch 13-14 Pulled cable	silver alloy		<b>√</b>	-
1CPSA4B-N	1/2 in NPT	4NC	9,9 [0.39] 7,9 [0.31] [0.5] Switch 21-22 Right 11-12 Switch 21-22 Pulled cable	silver alloy		✓	-

ABLE 6. 2CPS WITH BROKEN CABLE DETECTION AND SILVER ALLOY CONTACTS ORDER GUIDE								
Catalog Listing	Conduit	Switching	Bar Chart ■ Contact Closed ■ Contact Open	Standard Contact Block	Removeable Contact Block	Actuation	Pilot Light LED	Notes
2CPSA1A1	1/2 in NPT	2NO/2NC		$\checkmark$		Both		-
2CPSA1A1A	1/2 in NPT	2NO/2NC		✓		Both	24 Vdc	-
2CPSA1A1A-FW	1/2 in NPT	2NO/2NC		$\checkmark$		Both	24 Vdc	10-pin Brad Harrison connector; actuator to right
2CPSA1A1B	1/2 in NPT	2NO/2NC		$\checkmark$		Both	120 Vdc	-
2CPSA1A2	1/2 in NPT	2NO/2NC		$\checkmark$		Left only		-
2CPSA1A2A	1/2 in NPT	2NO/2NC		$\checkmark$		Left only	24 Vdc	-
2CPSA1A2A-FW	1/2 in NPT	2N0/2NC		$\checkmark$		Left only	24 Vdc	10-pin Brad Harrison connector; actuator to right
2CPSA1A2B	1/2 in NPT	2NO/2NC		$\checkmark$		Left only	120 Vdc	-
2CPSA1A3	1/2 in NPT	2NO/2NC		$\checkmark$		Right only		-
2CPSA1A3A	1/2 in NPT	2NO/2NC	$ \bigoplus_{9,9} \qquad \qquad \bigoplus_{9,9} $	$\checkmark$		Right only	24 Vdc	-
2CPSA1A3A-FW	1/2 in NPT	2NO/2NC	[0.39] [0.39] 12,7 7,9 3,8 3,8 7,9 12,7 [0.5] [0.31] [0.15] [0.31] [0.5]	$\checkmark$		Right only	24 Vdc	10-pin Brad Harrison connector; actuator to right
2CPSA1A3B	1/2 in NPT	2NO/2NC	Left         21-22           Switch         13-14	$\checkmark$		Right only	120 Vdc	-
2CPSA2A1	1/2 in NPT	2NO/2NC	Right 21-22		$\checkmark$	Both		-
2CPSA2A1A	1/2 in NPT	2NO/2NC	Switch 13-14		$\checkmark$	Both	24 Vdc	-
2CPSA2A1B	1/2 in NPT	2NO/2NC	Proper -		$\checkmark$	Both	120 Vdc	-
2CPSA2A2	1/2 in NPT	2NO/2NC	Slackened - cable - Pulled -		$\checkmark$	Left only		-
2CPSA2A2A	1/2 in NPT	2NO/2NC	cable tension cable		$\checkmark$	Left only	24 Vdc	-
2CPSA2A2B	1/2 in NPT	2NO/2NC			$\checkmark$	Left only	120 Vdc	-
2CPSA2A3	1/2 in NPT	2NO/2NC			$\checkmark$	Right only		-
2CPSA2A3A	1/2 in NPT	2NO/2NC			$\checkmark$	Right only	24 Vdc	-
2CPSA2A3B	1/2 in NPT	2NO/2NC			$\checkmark$	Right only	120 Vdc	-
2CPSC1A1	20 mm	2NO/2NC		$\checkmark$		Both		-
2CPSC1A1A	20 mm	2NO/2NC		$\checkmark$		Both	24 Vdc	-
2CPSC1A2	20 mm	2NO/2NC		$\checkmark$		Left only		-
2CPSC1A2A	20 mm	2NO/2NC		$\checkmark$		Left only	24 Vdc	-
2CPSC1A3	20 mm	2NO/2NC		$\checkmark$		Right only		-
2CPSC1A3A	20 mm	2NO/2NC		$\checkmark$		Right only	24 Vdc	-
2CPSC2A1A	20 mm	2NO/2NC			$\checkmark$	Both	24 Vdc	-

TABLE 6. 2CPS WITH	BROKEN CABLE DETI	ECTION AND SILVER ALLO	CONTACTS ORDER GUIDE					
CATALOG LISTING	CONDUIT	SWITCHING	BAR CHART CONTACT CLOSED CONTACT OPEN	STANDARD CONTACT BLOCK	REMOVEABLE CONTACT BLOCK	ACTUATION	PILOT LIGHT LED	NOTES
CPSA1B1	1/2 in NPT	1NO/3NC		$\checkmark$		Both		-
CPSA1B1A	1/2 in NPT	1NO/3NC		$\checkmark$		Both	24 Vdc	-
CPSA1B1A-F01	1/2 in NPT	1NO/3NC		$\checkmark$		Both	24 Vdc	10-pin Brad Harrison connector; actuator to right
2CPSA1B1B	1/2 in NPT	1NO/3NC		$\checkmark$		Both	120 Vdc	-
2CPSA1B2	1/2 in NPT	1NO/3NC	$\begin{array}{c} \bigoplus\\ 9,9 \end{array} \qquad \begin{array}{c} \bigoplus\\ 0 \end{array} \qquad \begin{array}{c} \bigoplus\\ 9,9 \end{array}$	$\checkmark$		Left only	120 Vdc	-
2CPSA1B2A	1/2 in NPT	1NO/3NC	[0.39] [0.39]	$\checkmark$		Left only	24 Vdc	-
2CPSA1B2A-F01	1/2 in NPT	1N0/3NC	12,7         7,9         3,8         3,8         7,9         12,7           [0.5]         [0.31]         [0.15]         [0.31]         [0.5]           Left         21-22	✓		Left only	24 Vdc	10-pin Brad Harrison connector actuator to right
CPSA1B2B	1/2 in NPT	1NO/3NC	Right 11-12	$\checkmark$		Left only	120 Vdc	-
CPSA1B3	1/2 in NPT	1NO/3NC	Switch 21-22	$\checkmark$		Right only		-
2CPSA1B3A	1/2 in NPT	1NO/3NC		$\checkmark$		Right only	24 Vdc	-
CPSA1B3A-F01	1/2 in NPT	1NO/3NC	Slackened - cable - Pulled cable tension cable	✓		Right only	24 Vdc	10-pin Brad Harrison connecto actuator to right
CPSA1B3B	1/2 in NPT	1NO/3NC		$\checkmark$		Right only	120 Vdc	-
CPSA2B1	1/2 in NPT	1NO/3NC			$\checkmark$	Both		-
CPSA2B1A	1/2 in NPT	1NO/3NC			$\checkmark$	Both	24 Vdc	-
CPSA2B1B	1/2 in NPT	1NO/3NC			$\checkmark$	Both	120 Vdc	-
2CPSC1D1A	20 mm	4NC	9,9       0       9,9         12.7       7,9       3.8       3.8       7.9       12.7         [0.5]       [0.31]       [0.15]       [0.31]       [0.5]         Left       11-12       1       1       1         Switch       21-22       1       1       1         Switch       21-22       1       1       1       1         Switch       21-22       1       1       1       1       1         Switch       21-22       1			Both	24 Vdc	-
CPSA1A4	1/2 in NPT	2NO/2NC	$\ominus$	$\checkmark$		Both		-
CPSA1A4B	1/2 in NPT	2NO/2NC	9.9 [0.39]	$\checkmark$		Both	120 Vdc	-
CPSA1A5B	1/2 in NPT	2NO/2NC	7.9 12.7	$\checkmark$		Left only	120 Vdc	-
CPSA1A6B	1/2 in NPT	2NO/2NC	0 [0.31] [0.5] Left 21-22	$\checkmark$		Right only	120 Vdc	-
CPSA2A4A	1/2 in NPT	2NO/2NC	Switch 13-14		$\checkmark$	Both	24 Vdc	-
CPSA2A4B	1/2 in NPT	2NO/2NC	Right 21-22		$\checkmark$	Both	120 Vdc	-
CPSC1A4-F02	20 mm	2NO/2NC	Switch 13-14 Pulled cable	✓		Both		No turnbuckles included

#### Figure 4. 1CPS Dimensional Drawing



#### Figure 5. 2CPS Dimensional Drawing



#### Figure 6. 1CPS Application Information







TABLE 10. ACCESSORIES/HARDWA	ARE PACKETS
Characteristic	Parameter
CLSZC1	Cable - 7,6 m [25 ft] length
CLSZC2	Cable - 15,2 m [50 ft] length
CLSZC3	Cable - 30,5 m [100 ft] length
CLSZC4	Cable - 45,7 m [150 ft] length
CLSZC5	Cable - 61 m [200 ft] length
CLSZC7	Cable - 76,2 m [250 ft] length
CLSZTC	<ul><li>(2) Thimbles</li><li>(2) Low-profile duplex cable clamps</li></ul>
CLSZ1S	(1) Draw-bar endspring
CPSZ1E	M6 x 1 x 60 mm eyebolt
CPSZ1S	(1) Draw-bar endspring
CPSZK1	<ul> <li>(1) J-hook turnbuckle with lock nuts</li> <li>(2) Thimbles</li> <li>(2) Low-profile duplex cable clamps</li> <li>(16) Sets of cable supports [(16) 1/4-20 eye bolts, (32) 1/4-20 nuts, (32) flat washers,</li> <li>(16) lock washers]</li> </ul>
CPSZK2	European hardware packet (1) J-hook turnbuckle with lock nuts (2) Thimbles (2) Stainless steel cable clamps (16) Sets of cable supports [(16) 1/4-20 eye bolts, (32) 1/4-20 nuts, (32) flat washers, (16) lock washers]
CPSZTB	J-hook turnbuckle with lock nuts (included with 2CPS)
CPSLED24	Multi-cluster LED accessory - 24 Vdc (conduit mount)
CPSLED120	Multi-cluster LED accessory - 120 Vac (conduit mount)
CPS-BRACKET	Mounting bracket (to be used with 1CPS or 2CPS)

## Figure 8. CPSLED Dimensional Drawing



- A Multi-LED red pilot light
- B 1/2-14 NPSM Thread
- C 18 AWG red PVC insulation
- D 18 AWG black PVC insulation

Figure 9. CPS-Bracket



#### **ADDITIONAL INFORMATION**

The following associated literature is available at sensing.honeywell.com:

- Product line guide
- Product part listing/nomenclature tree
- Product range guide
- CPS troubleshooting guide
- Electromechanical safety switch product selection guide
- Application note: MICRO SWITCH switches in conveyor applications

#### WARRANTY/REMEDY

Honeywell warrants goods of its manufacture as being free of defective materials and faulty workmanship during the applicable warranty period. Honeywell's standard product warranty applies unless agreed to otherwise by Honeywell in writing; please refer to your order acknowledgment or consult your local sales office for specific warranty details. If warranted goods are returned to Honeywell during the period of coverage, Honeywell will repair or replace, at its option, without charge those items that Honeywell, in its sole discretion, finds defective. The foregoing is buyer's sole remedy and is in lieu of all other warranties, expressed or implied, including those of merchantability and fitness for a particular purpose. In no event shall Honeywell be liable for consequential, special, or indirect damages.

While Honeywell may provide application assistance personally, through our literature and the Honeywell web site, it is buyer's sole responsibility to determine the suitability of the product in the application.

Specifications may change without notice. The information we supply is believed to be accurate and reliable as of this writing. However, Honeywell assumes no responsibility for its use.

# A WARNING PERSONAL INJURY

DO NOT USE these products as safety or emergency stop devices or in any other application where failure of the product could result in personal injury.

Failure to comply with these instructions could result in death or serious injury.

# WARNING MISUSE OF DOCUMENTATION

- The information presented in this product sheet is for reference only. Do not use this document as a product installation guide.
- Complete installation, operation, and maintenance information is provided in the instructions supplied with each product.

Failure to comply with these instructions could result in death or serious injury.

#### FOR MORE INFORMATION

Honeywell Advanced Sensing Technologies services its customers through a worldwide network of sales offices and distributors. For application assistance, current specifications, pricing or the nearest Authorized Distributor, visit our website or call:

USA/Canada +1 302 613 4491 Latin America +1 305 805 8188 Europe +44 1344 238258 Japan +81 (0) 3-6730-7152 Singapore +65 6355 2828 Greater China +86 4006396841

Honeywell Advanced Sensing Technologies 830 East Arapaho Road Richardson, TX 75081

sps.honeywell.com/ast

004785-7-EN | 7 | 01/22 © 2022 Honeywell International Inc. All rights reserved.

## Honeywell